



ANALYTICAL REPORT

PREPARED FOR

Attn: Water Report
NW Natural Water Services, LLC
107 S Main St
Coupeville, Washington 98239

Generated 6/7/2026 7:27:37 PM

JOB DESCRIPTION

Shirona Water- 78373F

JOB NUMBER

110-11484-1

Eurofins Washington

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Authorization



Generated
6/7/2026 7:27:37 PM

Authorized for release by
Crystal Deighton, Project Manager
Crystal.Deighton@et.eurofinsus.com
(360)757-1400

Client Sample Results

Client: NW Natural Water Services, LLC
Project/Site: Shirona Water- 78373F

Job ID: 110-11484-1

Client Sample ID: Shirona Water System

Lab Sample ID: 110-11484-1

Date Collected: 05/27/26 11:20

Matrix: Drinking Water

Date Received: 05/28/26 16:05

PWSID Number: 78373F

Method: 524.2 - Total Trihalomethanes

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Trihalomethanes, Total	73		0.50	ug/L		06/04/26 15:06	1	N4CJ

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Chloroform (Trichloromethane)	19		0.50	ug/L		06/04/26 15:06	1	HM3T
Bromodichloromethane	25		0.50	ug/L		06/04/26 15:06	1	HM3T
Dibromochloromethane	23		0.50	ug/L		06/04/26 15:06	1	HM3T
Bromoform	6.0		0.50	ug/L		06/04/26 15:06	1	HM3T

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
1,2-Dichloroethane-d4 (Surr)	98		70 - 130	06/04/26 15:06	1	HM3T
4-Bromofluorobenzene (Surr)	99		70 - 130	06/04/26 15:06	1	HM3T
Toluene-d8 (Surr)	94		70 - 130	06/04/26 15:06	1	HM3T

Method: 6251B - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Monobromoacetic acid	1.0		1.0	ug/L		06/04/26 18:41	1	QBD3
Monochloroacetic acid	ND		2.0	ug/L		06/04/26 18:41	1	QBD3
Dibromoacetic acid	5.8		1.0	ug/L		06/04/26 18:41	1	QBD3
Dichloroacetic acid	8.1		1.0	ug/L		06/04/26 18:41	1	QBD3
Trichloroacetic acid	8.1		1.0	ug/L		06/04/26 18:41	1	QBD3
Bromochloroacetic acid	9.0		1.0	ug/L		06/04/26 18:41	1	QBD3

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
2,3-Dibromopropionic acid	113		70 - 130	06/04/26 18:41	1	QBD3

Method: 6251B - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL	Unit	D	Analyzed	Dil Fac	Analyst
Total Haloacetic Acids 5	23		2.0	ug/L		06/04/26 18:41	1	YXX2

Action Limit Summary

Client: NW Natural Water Services, LLC
Project/Site: Shirona Water- 78373F

Job ID: 110-11484-1

Client Sample ID: Shirona Water System

Lab Sample ID: 110-11484-1

PWSID Number: 78373F

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Trihalomethanes, Total	73		ug/L	80	0.50	524.2	Total/NA
Chloroform (Trichloromethane)	19		ug/L	80	0.50	524.2	Total/NA
Bromodichloromethane	25		ug/L	80	0.50	524.2	Total/NA
Dibromochloromethane	23		ug/L	80	0.50	524.2	Total/NA
Bromoform	6.0		ug/L	80	0.50	524.2	Total/NA
Monobromoacetic acid	1.0		ug/L	60	1.0	6251B	Total/NA
Monochloroacetic acid	ND		ug/L	60	2.0	6251B	Total/NA
Dibromoacetic acid	5.8		ug/L	60	1.0	6251B	Total/NA
Dichloroacetic acid	8.1		ug/L	60	1.0	6251B	Total/NA
Trichloroacetic acid	8.1		ug/L	60	1.0	6251B	Total/NA
Total Haloacetic Acids 5	23		ug/L	60	2.0	6251B	Total/NA

Multiple WSI / ANALYSIS REQUEST

Page _ of _



110-11484 COC

ML (95)
1620 S Walnut St, Burlington, WA 98233
Bellingham (888-725-1212)
805 W Orchard Dr, Suite 4, Bellingham, WA 98225

Client & Billing Information

Report To: NW Natural Water Services

Ship Address: 102 SW Terry Road

City: Coupeville

Phone: 360-226-5007/360-226-4745

Email: wa.testing@nwnaturalwaterservices.com

Contact: Jessica Zimmer

Project Name: Shirona Water System

Bill To: KIN07

Address:

City:

Phone:

P.O.#

St: WA

Zip: 98239

St:

Zip:

INSTRUCTIONS

1. USE ONE LINE PER SAMPLE LOCATION.
2. BE SPECIFIC IN TEST REQUESTS.
3. CHECK OFF ANALYSIS TO BE PERFORMED FOR EACH SAMPLE LOCATION.
4. ENTER NUMBER OF CONTAINERS PER SAMPLE LOCATION.

Turn Around Time Requested

- ☒ STANDARD
☐ HALF-TIME (50% SURCHARGE)
☐ QUICKEST (100% SURCHARGE) PHONE CALL REQ.
☐ EMERGENCY (PHONE CALL REQUIRED)

Number of Containers

SPECIAL SOURCE NUMBERS

- 92 DISTRIBUTION (THM/HAA)
 96 BLENDED SAMPLE
 93 STANDING WATER (PB&CU)
 95 LAB COMPOSITE
 00 DISTRIBUTION (BACTERIA)

SPECIAL INSTRUCTIONS / CONDITIONS ON RECEIPT

SYSTEM ID	SOURCE#	SAMPLE LOCATION	DATE	TIME	Compliance	THM / HAA5	Number of Containers	SPECIAL INSTRUCTIONS / CONDITIONS ON RECEIPT
1 78373F	DIST	Shirona Water System	5/27/26	1120	☒	☒	6	
2					☐	☐		
3					☐	☐		
4					☐	☐		
5					☐	☐		
6					☐	☐		
7					☐	☐		
8					☐	☐		
9					☐	☐		
10					☐	☐		
SAMPLED BY: <i>N. Brown Campbell</i>							6	7 TOTAL CONTAINERS

PHONE: FAX: EMAIL:

YES ☐ NO ☐ N/A ☒

CUSTODY SEALS INTACT

SAMPLE TEMP 6.0 °C SATISFACTORY

EVIDENCE OF COOLING

SAMPLES RECEIVED INTACT

CHAIN OF CUSTODY & LABELS AGREE

DATE	TIME	RECEIVED BY	DATE	TIME
		<i>MLC</i>	5/28/26	1605
Edge PU01 5/28/26 1605				

FORM: WSI-Mult_WA.rpt

Environment Testing

[illegible]